

Public Swimming Pool and Spa Inspection Form

FACILITY NAME: _____ DATE: _____
 FACILITY ADDRESS: _____ COUNTY: _____
 OWNER/OPERATOR: _____ PHONE: _____
 MAILING ADDRESS: _____

Class A	Class B	Class D	Spa	Pre-10/01/99	Post-10/01/99			
Class C:	Apartment	HOA	Hotel/Motel	Country Club	School	Day Camp	Res. Youth Camp	Other

“X” Indicates a Deficiency

“C” – Indicates Corrected During Inspection

Italics indicate requirements for pools/spas constructed after October 1, 1999 only

Disinfection – 265.197 & 265.204		Signage – 265.199	
1. Automatic sanitizer dispenser.		36. Sign(s) visible to pool / spa user.	
2. Cl residual. Br residual.		37. “NO DIVING” 4" letters and 4" no diving symbol.	
3. pH (7.0 - 7.8).		38. “Warning-No Lifeguard On Duty” - 4" letters.	
4. DPD test kit.		39. “Children Should Not Use Pool w/o Adult Supervision” - 2" letters.	
5. No algae.		40. “In Case Of Emergency Dial 911” - 1" letters.	
6. Water clear – main drains visible.		41. <i>Pool maximum user load - 1" letters..</i>	
7. Operational logs.		Class A & B Facilities	
Mechanical – 265.187 & 265.188 & 265.189		42. Operator license(s) current.	
8. Pump functioning.		43. Water tested every 2 hours when pool in use (see log).	
9. Strainer and vacuum gauge on pump.		44. Rope & float line between shallow end & deep end.	
10. Flowmeter installed & functioning.		45. OSHA first aid kit and anti-disease transmission kit.	
11. Filter functioning.		46. Facilities clean and sanitary.	
12. Inlet, outlet gauges installed / functioning.		Bathhouse / Sanitary Facilities – 265.201	
13. Heater (over 200,000 BTU w/ TDLR certificate).		47. Private gender specific facilities.	
14. Heater installed downstream of filter.		48. Floor slip resistant and sloped to floor drain.	
15. Exposed piping labeled. Valves labeled.		49. Mirror & soap dispenser metal or plastic.	
Wading Pool – 265.184 & 265.185		50. Toilet paper & holders.	
16. Chlorine residual. Br residual.		51. Single use towels or blower.	
17. pH (7.0 - 7.8).		52. Covered waste receptacles.	
18. <i>15 feet from shallow / 35 feet from deepwater areas.</i>		Spa – 265.205	
19. <i>Fenced separately from pool / spa.</i>		53. Chlorine residual. Bromine residual.	
20. <i>Independent circulatory / sanitization system.</i>		54. pH (7.0 - 7.8).	
Skimmers / Returns – 265.191		55. Temperature not over 104°F / Spa thermometer available to users.	
21. Skimmer cover and basket intact and in place.		56. Minimum 2 depth markers on deck - 4" numbers <i>& letters.</i>	
22. Skimmer basket free of debris and sanitizer.		57. Maximum user load limit sign provided.	
23. Equalizer outlet with approved cover or sealed.		58. “Children Should Not Use Spa w/o Adult Supervision” - 2" letters.	
Structural Design – 265.184		59. “Do Not Use Spa if Temp. Is Above 104°F” - 1" letters.	
24. Pool / spa bottom & sides white or light color.		60. Emergency shutoff switch in sight & minimum 5 ft. away.	
25. <i>Toe tile on leading edge of steps, benches, swimouts.</i>		61. <i>15 min. timer switch minimum 5 feet away from spa.</i>	
Fill Water / Wastewater – 265.194 & 265.195		Electrical – 265.192	
26. Potable water supply.		62. GFCI's installed.	
27. Water distribution system protected against backflow.		63. <i>Service electrical disconnect within sight of equipment.</i>	
28. Over-the-rim fill spout with secure soft pliable end.		Food, Beverages & Containers – 265.202	
29. <i>Drinking water fountain available to pool / spa users.</i>		64. No glass containers in pool yard.	
Depth Markers - Pools – 265.199		65. Trash containers provided in pool yard.	
30. Deck & sidewall depth markers present - 4" numbers.		Diving Facilities – 265.186 (see Lifeguards)	
31. No more than 25 feet apart.		66. Boards / platforms over 1 M w/dual dual guard & hand rails.	
32. At max. & min. depth, break point & 2' depth intervals.		67. Boards / platforms ½ - 1 M w/single guard & hand rails.	
33. 4" “No Diving” letters & symbol in shallow areas on deck.		68. Minimum distance between multiple boards 10 feet.	
34. “No Diving” deck markers no more than 25 feet apart.		69. Lifeguard chair(s) at least 4 feet above deck.	
35. <i>Feet and / or inches in 4" letters.</i>		70. <i>Diving board(s) properly labeled.</i>	

Specific Safety Features – 265.199		Suction Outlets (Main Drains) – 265.199	
71. Min. 12' non-conductive reaching pole within 20' of pool.		81. Single. Dual.	
72. USCG ring buoy w/throw rope within 20' of pool.		82. Suction outlet cover(s) / grate(s) intact and in place.	
73. Emergency summoning device (phone).		83. SVRD / AVS installed when required.	
74. Phone location sign visible in pool / spa yard (if required).		84. Vacuum outlet with cover and auto-latch or filled in.	
75. 4" x 4" visible bottom stripe at shallow to deep transition.		85. Check valve(s) up stream of pump.	
		Gas Chlorination – 265.198	
Lifeguards – 265.199		86. Two trained personnel.	
76. Current license(s) available.		87. Chlorine stored in vented room.	
77. Second responder.		88. Proper signage & view port on housing door(s).	
78. Sufficient number of rescue tubes.		89. Appropriate safety equipment & respirator.	
79. Backboard with 3 tie-down straps & head immobilizer.		90. Scale & ammonia solution.	
80. First aid kit with anti-disease transmission capabilities.		91. Electrical switches outside chlorine gas storage room.	

POOL ENCLOSURES

All Class C, Class D, and Day Camp Pools & Spas		102. Latch 42" or less above ground & opens w/ key, card or comb.	
92. Minimum 48-inch height.		103. No chain link after 01/01/04.	
93. Gate(s) self-closing and self-latching & not propped open.		Class C & D Pools & Spas Subject to HSC 757 - Pre-01/01/94	
94. No openings under fence allow passage of 4" sphere.		104. Horizontal bars 36" apart with no openings greater than 4".	
Class C & D Pools & Spas Subject to HSC 757 - Post-01/01/94		105. Door w/ keyed deadbolt, keyless bolt device or throw bolt.	
95. Horizontals 45" or more apart w/ no gaps greater than 4".		106. Door with latch, closure device and bolting device.	
96. Horizontals less than 45" apart / no gaps greater than 1-3/4".		107. Sliding door with handle latch or bar and sliding pin lock.	
97. No fence cutouts w/ gaps greater than 1-3/4 inches.		C & D & Day Camp Pools & Spas Not Subject to HSC 757 or Local Codes	
98. Gate(s) opens outward & can be locked.		108. Horizontals 45" or more apart w / no gaps greater than 4".	
99. Latch inside & 3" below top of gate.		109. No structures within 36" allowing fence to be scaled.	
100. Latch inside & no opening 1/2" or more 18" around latch.		110. Opening hardware min. 42" above ground and can be locked.	
101. Latch outside & minimum 60" above ground.		112. Gate(s) / door(s) open outward & can be locked.	
ALL CLASS A & B AND ALL RESIDENTIAL YOUTH CAMP POOL ENCLOSURES - 265.200			
113. Minimum fence height 6 feet.		116. Gate(s) / Door(s) capable of being locked.	
114. Gaps less than 4 inches.		117. Gate(s) / Door(s) directly supervised or locked.	
115. Designed to be difficult to scale.		118. No openings from private premise into pool / spa yard.	

Comments:

This image shows a single sheet of white paper with horizontal blue or grey ruling lines. The lines are evenly spaced and run across the width of the page. There are approximately 20 lines visible. The paper has a slight shadow on its right side, suggesting it's resting on a surface.

Inspected by: _____ Owner/Operator: _____

Print Name: _____ Print Name: _____